- <sup>2</sup> See Mineral Dusts Table.
  <sup>3</sup> Use Asbestos Limit § 1926.58.
  <sup>4</sup> See 1926.58.
  <sup>4</sup> See 19ELs are 8-hour TWAs unless otherwise noted; a (C) designation denotes a ceiling limit.
  <sup>\*\*</sup> As determined from breathing-zone air samples.
  <sup>a</sup> Parts of vapor or gas per million parts of contaminated air by volume at 25 °C and 760 torr.
  <sup>b</sup> Milligrams of substance per cubic meter of air. When entry is in this column only, the value is exact; when listed with a ppm entry, it is approximate.
  <sup>c</sup> [Reserved]
- [Reserved]

  The CAS number is for information only. Enforcement is based on the substance name. For an entry covering more than one metal compound, measured as the metal, the CAS number for the metal is given—not CAS numbers for the individual compounds.
- e f [Reserved]

- For sectors excluded from § 1926.1128 the limit is 10 ppm TWA.

  [Reserved]

  Millions of particles per cubic foot of air, based on impinger samples counted by light-field techniques.
- \*The percentage of crystalline silica in the formula is the amount determined from airborne samples, except in those instances in which other methods have been shown to be applicable. 

  \*[Reserved]

  \*\*Covers all organic and inorganic particulates not otherwise regulated. Same as Particulates Not Otherwise Regulated.

  \*\*If the exposure limit in § 1926.1126 is stayed or is otherwise not in effect, the exposure limit is a ceiling of 0.1 mg/m³.

  \*\*If the exposure limit in § 1926.1126 is stayed or is otherwise not in effect, the exposure limit is 0.1 mg/m³ (as CrO₃) as an 8-hour TWA.

  \*\*The 1970 TIV uses letter designations instead of a numerical value as follows:

The 1970 TLV uses letter designations instead of a numerical value as follows:

The 1970 TLV uses letter designations instead of a numerical value as follows:

A¹[Reserved]

A²Polytetrafluoroethylene decomposition products. Because these products decompose in part by hydrolysis in alkaline solution, they can be quantitatively determined in air as fluoride to provide an index of exposure. No TLV is recommended pending determination of the toxicity of the products, but air concentrations should be minimal.

A³Gasoline and/or Petroleum Distillates. The composition of these materials varies greatly and thus a single TLV for all types of these materials is no longer applicable. The content of benzene, other aromatics and additives should be determined to arrive at the appropriate TLV.

E Simple asphyxiants. The limiting factor is the available oxygen which shall be at least 19.5% and be within the requirements addressing explosion in part 1926.

[39 FR 22801, June 24, 1974, as amended at 51 FR 37007, Oct. 17, 1986; 52 FR 46312, Dec. 4, 1987; 58 FR 35089, June 30, 1993; 61 FR 9249, 9250, Mar. 7, 1996; 61 FR 56856, Nov. 4, 1996; 62 FR 1619, Jan. 10, 1997; 71 FR 10381, Feb. 28, 2006; 71 FR 36009, June 23, 2006]

## § 1926.56 Illumination.

General. Construction areas. (a.) ramps, runways, corridors, offices, shops, and storage areas shall be lighted to not less than the minimum illumination intensities listed in Table D-3 while any work is in progress:

TABLE D-3-MINIMUM ILLUMINATION INTENSITIES IN FOOT-CANDLES

Foot-candles	Area or operation
53	General construction area lighting. General construction areas, concrete placement, excavation and waste areas, accessways, active storage areas, loading platforms, refueling, and field maintenance areas.
5	Indoors: warehouses, corridors, hallways, and exitways.
10	Tunnels, shafts, and general underground work areas: (Exception: minimum of 10 foot-candles is required at tunnel and shaft heading during drilling, mucking, and scaling. Bureau of Mines approved cap lights shall be acceptable for use in the tunnel heading.)  General construction plant and shops (e.g., batch plants, screening plants, mechanical and electrical equipment rooms, carpenter shops, rigging lofts and active storerooms, barracks or living quarters, locker or dressing rooms, mess halls, and indoor toilets and work-
30	rooms). First aid stations, infirmaries, and offices.

(b) Other areas. For areas or operations not covered above, refer to the American National Standard A11.1-1965, R1970, Practice for Industrial Lighting, for recommended values of illumination.

## § 1926.57 Ventilation.

- (a) General. Whenever hazardous substances such as dusts, fumes, mists, vapors, or gases exist or are produced in the course of construction work, their concentrations shall not exceed the limits specified in §1926.55(a). When ventilation is used as an engineering control method, the system shall be installed and operated according to the requirements of this section.
- (b) Local exhaust ventilation. Local exhaust ventilation when used as described in (a) shall be designed to prevent dispersion into the air of dusts, fumes, mists, vapors, and gases in concentrations causing harmful exposure. Such exhaust systems shall be so designed that dusts, fumes, mists, vapors, or gases are not drawn through the work area of employees.
- (c) Design and operation. Exhaust fans, jets, ducts, hoods, separators, and all necessary appurtenances, including